

PFAS6 Monthly Results & Quarterly Averages: 2021

Treatment Plant	Springvale WTP		Elm Bank WTP	Pine Oaks WTP	Morses Pond WTP	MCL (ppt)	QC complete (Y/N)
EPTDS Location	Tonka	H&T	Elm Bank	Pine Oaks	Morses Pond		
January	19.7	25.1	11.3	14.8	32.9	20	Y
February	22.9	24.6	9.97	20	76.6		Y
March							
Quarter 1 Averages							N/A
April						20	
May							
June							
Quarter 2 Averages							N/A
July						20	
August							
September							
Quarter 3 Averages							N/A
October						20	
November							
December							
Quarter 4 Averages							N/A

KEY:

EPTDS = Entry Point To Distribution System, this is "Finished" or treated water

PPT = Parts Per Trillion, also equal to ng/L

MCL = Maximum Contaminant Level (highest amount allowed by regulation)

QC = Quality Control report, this determines if a sample result is valid or invalid for various lab processing reasons

NOTES

Yellow highlight = Result exceeds MCL (Note: only a Quarterly average exceedance is in violation of regulation)

Compliance/Violation with regulation based on locational **Quarterly Averages**

Morses Pond is currently an inactive source